

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 19/03/2026

It is certified that an inspection team headed by ...Shivaji Maurya (Lab Incharge)

(Name of Officers with designation) from U.P. Jal Nigam Lab, PHED

inspected the Blooming Buds Public School, Balrampur - Gonda road

(Name & Address of the school) on 23/03/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. BA/3340/03/2026 dated 23/03/2026

of U.P. Jal Nigam Laboratory (PHED Lab) certified that


the Blooming Buds Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 23/09/2026

Signature with Seal: 

Name : Shivaji Maurya

Designation : Lab Incharge

Name & Address of the Office / Department : U.P. Jal Nigam (L)

Utrauda, Balrampur  
271604

To

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



## Analysis Report

### DISTRICT LEVEL WATER ANALYSIS LABORATORY

(An NABL Accredited Laboratory)

U.P. Jal Nigam (Rural), Utraula, Balrampur-271604



TC-12131

Rept No.	3340	Date	23.03.2026	Page .No.	1
Customer Details	Blooming buds Public School				
Office Name and Address	Balrampur-Gonda Road Mau Shamshabad, Gonda Pin-271209				
Ref Letter No & Date	NA				
Basic details of sample					
District	Gonda	Block	Rupaideeh		
Gram Panchayat	Mau Shamshabad	Village	Mau Shamshabad		
Habitation	Mau Shamshabad	Location	Blooming buds Public School		
Water Source	Tap Water	Sample No.	BAL/3340/03/2026		
Quantity of Sample	1 LTR.	Date of Sample Collection	19.03.2026		
Receiving Date:	19.03.2026	Sample Collector	Rakesh Kumar		
Sample Depositer					
Analysis Start Date	19.03.2026	Analysis Completion Date	23.03.2026		
Temperature	25±3 °C	Humidity	50±15%		

#### Technical Data of Analysis

S. No.	Parameter	Units	Observed Value	Specified Values as per		Ref. Method of Analysis
				Acceptable limit	Permissible Limit	
1	2	3	4	5	6	7
1	Odour	(Dt&Rt)	Odour less	Agreeable	No Relaxation	IS 3025 (Part 5) : 2021
2	Taste	(Dt&Rt)	Agreeable	Agreeable	No Relaxation	IS 3025 (Part 8) : 2023
3	Turbidity	(NTU)	0.12	1.00	5.00	IS 3025 (Part 10) : 2023
4	pH Value	(mg/L)	7.27	6.5-8.5	6.5-8.6	IS 3025 (Part II) : 2022
5	TDS	(mg/L)	126.50	500.00	2000	IS 3025 (Part 16) : 2023
6	Fluoride	(mg/L)	0.08	1.00	1.5	IS 3025 (Part 60) : 2022
7	Chloride	(mg/L)	15.33	250.00	1000	IS 3025 (Part 32) : 2019
8	Total Alkalinity	(mg/L)	92.40	200.00	600	IS 3025 (Part 23) : 2023
9	Nitrate	(mg/L)	2.95	45.00	100	APHA 4500 : 24 edison
10	Sulphate	(mg/L)	12.30	200.00	400	IS 3025 (Part 24/sec 1) : 2022
11	Iron	(mg/L)	0.120	0.01	1	IS 15303 : 2018
12	Total Hardness	(mg/L)	127.60	200.00	600	IS 3025 (Part 21) : 2019
13	Calcium	(mg/L)	66.0	75.00	200	IS 3025 (Part 40) : 2019
14	Magnisium	(mg/L)	61.0	30.00	100	IS 3025 (Part 46) : 2023

#### Note:-

1. This Certificate refers only to the particular sample(s) submitted for analysis.
2. This Certificate shall not be reported, except in full, unless written permission for the publication of an approved abstract has been obtained
3. The test result reported in this certificate are valid at the time of and under the stated condition of measurements.
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless.
5. Parameter above Permissible limit are written in **Bold**.
6. Laboratory is responsible for all information given in the report
7. Laboratory is not collected sample from the source.
8. This certificate valid only one year from the date of issue of tests reports

Result approved by  
**T. Shivaji Mishra**  
District Level Water Analysis Laboratory  
Balrampur U.P. J.N.

\*\*\* END OF THE TEST REPORT\*\*\*

Laboratory Contact details-Email-upjnlabbalrampur09@gmail.com, Mob-9695410707